

Fw: 2nd Qtr. 2024 - DBP Summary (Hurt)

From Town of Hurt Public Works <publicworks@townofhurtva.gov>
 Date Thu 6/12/2025 2:32 PM
 To Gary Hodnett <gary.hodnett@townofhurtva.gov>
 Cc Paul Watlington <publicworks2@townofhurtva.gov>

From: Merricks, T. (VDH) <Chad.Merricks@vdh.virginia.gov>
 Sent: Tuesday, June 18, 2024 2:29 PM
 To: Town of Hurt Public Works <publicworks@townofhurtva.gov>
 Cc: Prillaman, Rea (VDH) <Rea.Prillaman@vdh.virginia.gov>; Haun, Matthew (VDH) <Matthew.Haun@vdh.virginia.gov>
 Subject: 2nd Qtr. 2024 - DBP Summary (Hurt)

Re: VA5143246 - Hurt, Town of
 DBPs Sample Results 2nd Qtr. 2024

Attached is a review the results of total trihalomethane (TTHM) and haloacetic acid (HAA5) analyses that were performed on water samples collected during the second quarter (April - June) 2024. The summary compliance chart for each sampling location is provided below.

The TTHM maximum contaminant level is 0.080 mg/L and the HAA5 maximum contaminant level is 0.060 mg/L. Compliance with the TTHM and HAA5 maximum contaminant levels is based on the four-quarter locational running annual average(s) (LRAA). The operational evaluation level (OEL) is also calculated on a quarterly basis and compared to the maximum contaminant levels as an early warning sign.

Based on the results, the waterworks is in compliance with the TTHM and HAA5 maximum contaminant levels. In addition the waterworks has not exceeded a TTHM or HAA5 operational evaluation level.

Thus, continue routine quarterly TTHM / HAA5 sampling, with your next set due within September 2024.

If you have any questions, please feel free to contact the Danville Field Office.
 Additional sampling information and schedules may be found at [Home - Drinking Water Viewer \(gecsws.com\)](#).

0.024 MG/L VA5143246 HURT, TOWN OF 92734720001HAA 6/5/2024 RT 2456 TOTAL HALOACETIC ACIDS (HAA5) DBP01
 0.063 MG/L VA5143246 HURT, TOWN OF 92734720001THM 6/5/2024 RT 2950 TTHM DBP01

Site		Summary Type	Monitoring Period Combined	Monitoring Period		Locational Running Annual Avg		Exceeds MCL	Operational Evaluation Level	
Sampling Point	Sample Location			Begin Date	End Date	# of Samples	Average		# of Samples	Average
DBP01	708 PROSPECT ROAD	TTHM with MCL 80 ug/L	04/01/2024 - 06/30/2024	4/1/2024	6/30/2024	4	52 ug/L	N	3	51 ug/L
DBP01	708 PROSPECT ROAD	HAA5 with MCL 60 ug/L	04/01/2024 - 06/30/2024	4/1/2024	6/30/2024	4	29 ug/L	N	3	28 ug/L
DBP01	708 PROSPECT ROAD	TTHM with MCL 80 ug/L	01/01/2024 - 03/31/2024	1/1/2024	3/31/2024	4	55 ug/L	N	3	47 ug/L
DBP01	708 PROSPECT ROAD	HAA5 with MCL 60 ug/L	01/01/2024 - 03/31/2024	1/1/2024	3/31/2024	4	31 ug/L	N	3	32 ug/L
DBP01	708 PROSPECT ROAD	TTHM with MCL 80 ug/L	10/01/2023 - 12/31/2023	10/1/2023	12/31/2023	4	54 ug/L	N	3	53 ug/L
DBP01	708 PROSPECT ROAD	HAA5 with MCL 60 ug/L	10/01/2023 - 12/31/2023	10/1/2023	12/31/2023	4	32 ug/L	N	3	30 ug/L
DBP01	708 PROSPECT ROAD	TTHM with MCL 80 ug/L	07/01/2023 - 09/30/2023	7/1/2023	9/30/2023	4	61 ug/L	N	3	63 ug/L
DBP01	708 PROSPECT ROAD	HAA5 with MCL 60 ug/L	07/01/2023 - 09/30/2023	7/1/2023	9/30/2023	4	39 ug/L	N	3	32 ug/L

T. Chad Merricks
 Environmental Health Specialist Consultant

Office of Drinking Water - Danville
 211 Nor Dan Drive, Suite 1040
 Danville, VA 24540
 Phone: (434) 836-8416
 Cell: (434) 770-4860
 Fax: (434) 836-8424
[Home - Drinking Water Viewer \(gecsws.com\)](#)