

Annual Drinking Water Quality Report for 2025

Town of Hurt PWS ID No. 5143246

web: townofhurtva.gov

INTRODUCTION

This Annual Drinking Water Quality Report for the 2025 calendar year is designed to inform you about your drinking water quality. Our goal is to provide you with a safe and dependable supply of drinking water, and we want you to understand the efforts we make to protect your water supply. The quality of your drinking water must meet state and federal requirements administered by the Virginia Department of Health (VDH).

If you have questions about this report, and want additional information about any aspect of your drinking water or want to know how to participate in decisions that may affect the quality of your drinking water, please contact:

Gary Hodnett, Mayor or **Joseph Smith**, Public Works Coordinator

Phone: (434) 608-0554 email: gary.hodnett@townofhurtva.gov or publicworks@townofhurtva.gov

The times and location of regularly scheduled Council meetings are as follows:

First Tuesday of each month at 7:00 p.m. – Council Chambers, Municipal Building
533 Pocket Road, Hurt, VA. 24563

GENERAL INFORMATION

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity. Contaminants in source water may be naturally occurring substances, or may come from septic systems, discharges from domestic or industrial wastewater treatment facilities, agricultural and farming activities, urban stormwater runoff, residential uses, and many other types of activities. Water from surface sources is treated to make it drinkable while groundwater may or may not have any treatment.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil / gas production & mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

All drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

VULNERABLE POPULATIONS

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

SOURCE(S) AND TREATMENT OF YOUR DRINKING WATER

The source of your drinking water is water purchased from the Town of Altavista water supply. The Town of Altavista's sources of water include surface supplies from the Staunton River and Reed Creek. Two groundwater (spring) sources, McMinnis Spring and Reynolds Spring, also supplement the Town's water supply, but the water delivered to the Town of Hurt is pumped directly from Altavista's water treatment plant.

Treatment of the raw surface water sources consists of chemical addition, coagulation, flocculation, settling, filtration, fluoridation, corrosion control, and chlorination. All these processes work together to remove the physical, chemical, and biological contaminants to make the water safe for drinking.

A source water assessment for the Town of Altavista's, our water supplier, was conducted in 2003 by the Virginia Department of Health. The river was determined to be of high susceptibility to contamination using the criteria developed by the state in its approved Source Water Assessment Program.

The assessment report consists of maps showing the source water assessment area, an inventory of known land use activities of concern, and documentation of any known contamination within the last 5 years. The report is available from your water system representatives: Mayor Gary Hodnett or Public Works Coordinator Joseph Smith at (434) 608-0554.

WATER CONSERVATION TIPS

Did you know that the average U.S. household uses approximately 350 gallons of water per day? Luckily, there are many low-cost or no-cost ways to conserve water. Water your lawn at the least sunny times of the day. Fix toilet and faucet leaks. Take short showers - a 5-minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath. Turn the faucet off while brushing your teeth and shaving; 3-5 gallons go down the drain per minute. Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!

DEFINITIONS

Contaminants in your drinking water are routinely monitored according to federal and state regulations. The table on the next page shows the results of this monitoring for the period of January 1st through December 31st, 2023. In the table and elsewhere in this report you will find many terms and abbreviations you might not be familiar with. The following definitions are provided to help you better understand these terms:

Non-detects (ND) - lab analysis indicates the contaminant is not detectable, based on the limits of the analytical equipment used.

Parts per million (ppm) or Milligrams per liter (mg l) - one part per million corresponds to one minute in two years or one penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (µg l) - one part per billion corresponds to one minute in 2,000 years, or one penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (ng l) - one part per trillion corresponds to one minute in 2,000,000 years, or one penny in \$10,000,000,000.

Picocuries per liter (pCi L) - picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) - nephelometric turbidity unit is a measure of the cloudiness of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Variances / exemptions - state or EPA permission not to meet an MCL or a treatment technique under certain conditions.

2025 Town of Hurt Consumer Confidence Report (CCR)

WATER QUALITY RESULTS

We routinely monitor for various contaminants in the water supply to meet all regulatory requirements. The table lists only those contaminants that had some level of detection. Many other contaminants have been analyzed but were not present or were below the detection limits of the lab equipment.

Town of Hurt

Lead and Copper						
Contaminant / Unit of Measurement	MCLG	MCL	Level Found / Range	Violation	Date of Sample	Typical Source of Contamination
Copper (ppm)	1.3	AL = 1.3	0.1 (90 TH Percentile) Range: 0.02 to 0.0845 Of the ten samples collected: none exceeded the Action Level	No	July 2023	Corrosion of household plumbing systems
Lead (ppb)	0	AL = 15	The (90 TH Percentile) was <2 All samples were below the detection Limit	No	July 2023	Corrosion of household plumbing systems
Disinfection Byproducts						
Contaminant / Unit of Measurement	MCLG	MCL	Highest LRAA / Range Found	Violation	Date of Sample	Typical Source of Contamination
HAA5's (Total Haloacetic Acids) (ppb)	N/A	60	Highest Level 31 Range: 21 - 26	No	Quarterly	By- product of drinking water disinfection
TTHM (Total Trihalomethanes) (ppb)	N/A	80	Highest Level: 61 Range: 31 - 86	No	Quarterly	By- product of drinking water disinfection
Chlorine (ppm)	MRDLG =4	MRDL =4	Avg: 1.14 Range: .47- 1.60	No	Tested Monthly	Water additive used to control microbes

Town of Altavista

REGULATED CONTAMINANTS

Contaminant- Unit of Measurement	Testing Frequency or Sample Date	Highest Level Detection	Range of Detection	MCL	MCLG	Typical Source of Contamination	Violation
Fluoride (ppb)	Tested Daily	1.02	0.092- 1.02	4	4	Water additive which promotes teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories	No
Nitrate- Nitrite (ppb)	November 2025	0.17	0.13- 0.17	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits	No

2025 Town of Hurt Consumer Confidence Report (CCR)

Town of Altavista (CONT.)

REGULATED CONTAMINANTS

Contaminant- Unit of Measurement	Testing Frequency or Sample Date	Highest Level Detected	Range of Detection	MCL	MCL G	Typical Source of Contamination	Violation
Copper (ppb)	July, 2023	0.298 90 TH Percentile	.0047- 0.46 0 of 20 Samples Exceeded AL	AL = 13	1.3	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives	No
Lead (ppb)	July, 2023	1.2 90 TH Percentile	<0.5- 5 0 of 20 Samples Exceeded AL	AL= 15	0	Corrosion of household plumbing systems	No
Atrazine (ppb)	April, 2025	ND	ND	3	3	Runoff from herbicides used on crops	No
Barium-ppb	October 2025	0.103	0.0191- 0.103	2	2	Discharge of drilling waste: discharge from metal refiners: erosion of natural deposits	No
Cadmium-ppb	October 2025	0.038	ND	5	5	Corrosion of galvanized pipes, erosion of natural deposits, discharges from metal refineries, runoff from waste batteries and paints	No
Chromium-ppb	October 2025	0.0014	ND-0.0014	100	100	Contamination from discharge from steel and pulp mills, erosions of natural deposits	No
Turbidity – NTU	Tested continuously at Water Plant	0.07 100% Less than .30	.016 - .118	TT= 1 MAX TT=< 0.3 in 95% of monthly samples	N/A	Soil Runoff	No
Gross Alpha – pCi/l	April, 2024	0.256	0.171-.256	15	0	Erosion of Natural Deposits	No
Combined Radium – pCi/l	April, 2024	0.0840	0.737- .0840	5	0	Erosion of Natural Deposits	No
Chlorine - ppm	Continuously at Water Plant and Distribution System	Highest Level: 2.20	0.35-2.20	MDRL 4	MDR LG4	Water Additives used for disinfection	No

Town of Altavista (CONT.)							
REGULATED CONTAMINANTS							
Total Organic Carbon (TOC) - ppm Removal Ratio	Tested Monthly	12-month Lowest Ratio 1.08	0.55-1.76	TT Ratio $\geq$ 1.0 Or Alternate Compliance	N/A	Naturally present in the environment	No
Site #1 Exxon		LRRA					
Unregulated contaminants	UCMR4 2019					All results Available upon request HFPDO with a result of .0062	
Unregulated Contaminants	UCMR5 2023					All results Available upon request HFPDO with a result of .0062 PFBA result of .0076	

Unregulated Contaminant

The Town of Altavista was chosen to participate in the UCMRS (Unregulated Contaminate Monitoring Rule) by the EPA. Out of 220 tests ran, we had one HFPDO with a result of .0062 in 2019. The same contaminant was again .0062 in 2023. We also had one PFBA result of .0076 in 2023. The water plant has a complete list of PFAS tested and can be obtained by contacting 434-324-7251.

Hexafluoropropylene Oxide (HFPO) Dimer Acid- HFPO dimer acid and its ammonium salt are referred to as "Gen X chemicals" because they are two of the main chemicals associated with the Gen X processing aid technology that DuPont developed to make high performance fluoropolymers without using perfluorobutanoic acid.

Perfluorobutanoic Acid (PFBA) This group of chemicals is commonly used in non-stick and stain-resistant consumer products, food packaging, fire-fighting foam, and industrial processes.

Some results are from previous years as sampling for these contaminants is done less frequently than annually. The state allows us to monitor some contaminants less than once per year because the concentration of these contaminants does not change frequently. Some of our results, though representative, are more than one year or were below the detection limits of the lab equipment.

ADDITIONAL INFORMATION FOR LEAD

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials, and components associated with service lines and home plumbing. The Town of Hurt is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 15 to 30 seconds or until it becomes cold or reaches a steady temperature before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure are available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

2025 Town of Hurt Consumer Confidence Report (CCR)

Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.

ADDITIONAL INFORMATION THAT YOU MAY BE INTERESTED IN:

The U.S. Environmental Protection Agency sets MCL's at very stringent levels. In developing the standards EPA assumes that the average adult drinks 2 Liters of Water each day: throughout a 70-year life span. EPA generally sets MCL's at levels that will result in no adverse health effects for some contaminants or a one-in-ten thousand to one-in-one-million chance of having the described health effect for other contaminants.

There is no state or federal MCL for sodium. Monitoring is required to provide information to consumers and health officials that are concerned about sodium intake due to dietary precautions. The sodium high level in your water was 5.6 ppm as tested in 2025 with a range of 2.4- 11.2 ppm. People on, sodium -restricted diet should consult a physician about the: level of sodium in water they drink.

The Town of Altavista also provides water to the Town of Hurt. The Town of Hurt purchased 27,783,900 gallons in the year 2025. Part of which Hurt provides to the Grit community.

The Town of Hurt also completed a lead line inventory of all connections to each meter in 2024. Access to this list is on the Town Website. Once on site, go to the bottom right corner and click on Public Works icon. Then click on lead and copper inventory. You can search for your address. You will also need to zoom in at 500% to read the document information. Please contact Hurt Town Hall if you have any questions.

The Town of Hurt is complying with all mandates set forth in the Virginia Department of Health's Consent Order. We continue in-house evaluations and consultations with the Virginia Department of Health's Office of Drinking Water. We are working with the Town of Altavista to coordinate monitoring of disinfection byproducts in our distribution system.

The CCR report this year will not be posted in the local newspaper and will not be mailed or hand delivered, however a copy can be obtained by contacting the Hurt Town Hall 533 Pocket Road at 434-608-0554 between the hours of 8:00 am and 5:00 pm. And will be available upon request at the Town Hall 533 Pocket Road Hurt VA. 24563. It can also be accessed by the following link townofhurtva.gov/public-works/pages/water-quality